



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7162-2320:0500
<b>CATEGORY:</b>	7162 - FIRE RESISTIVE CABLES
<b>LISTEE:</b>	RFS Technologies, Inc. 200 Pondview Drive, Meriden, CT, 06450 Contact: Xu, Wilson 4753550158 Email: wilson.xu@rfstechnologies.com
<b>DESIGN:</b>	Model 2HB12-50JPLR DragonSkin CATVP Coaxial Cable.  Refer to listee's data sheet for detailed product description and operational considerations.
<b>RATING:</b>	Circuit Integrity Rating: 2 hr  Max Voltage: 50 Vac line to line, 29 Vac line to ground
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, NEC Article 820, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and UL label.
<b>APPROVAL:</b>	Listed as a fire-resistive cable for use in System No. FHIT.1250. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

06-16-20 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 09/06/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division