

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7162-2320:0500

CATEGORY: 7162 -- FIRE RESISTIVE CABLES

LISTEE: Radio Frequency Systems 200 Pondview Drive, Meriden, CT 06450
Contact: Sarah Siniscalco (203) 630-3311 Ext: 1163
Email: sarah.siniscalco@rfsworld.com

DESIGN: Model 2HB12-50JPLR DragonSkin CATVP Coaxial Cable.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Circuit Integrity Rating: 2 hr
Max Voltage: 50 Vac line to line, 29 Vac line to ground

INSTALLATION: In accordance with listee's printed installation instructions, NEC Article 820, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as a fire-resistive cable for use in System No. FHIT.1250. Refer to listee's Installation Instruction Manual for details.

06-16-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division